



# GGP46.8 GENSET

# Generating Set Powered By Perkins STAMFORD

Image for illustration purposes only

# **Output Ratings**

Generating Set Model	Prime Power	Standby Power
1500rpm, 50 Hz / 400V	34KWe / 42.5KVA	37.4KWe / 46.8KVA
1800rpm, 60 Hz / 440V	42KWe / 52.5KVA	45KWe /56.3KVA

# **Genset Specifications**

Engine Make & Model	Perkins   103A33-TG
Origin	UK
<b>Alternator Type</b>	Stamford PI144K
Control Panel	Deap Sea - 6110
Circuit Breaker Type	3 Pole MCB

## **Water Cooling System**

**Mechanical Governor** 

**Electrical Stop Solenoid, Energized to Run** 

**Compact Size** 

## **Fuel System**

1500rpm, 50 Hz

1800rpm, 60Hz	5.46	7.74	10.1
*Prime Power (I/hr)	6.95	9.7	12.64

# **International Standards**

Engine confirm to ISO 9001: 2000, ISO 14001, ISO 10054, ISO 3046, BS 5514, DIN 6271.

Alternator confirm to ISO 9001, ISO 14001, BS EN 60034, BS 5000, VDE 0530, NEMA MG32-1, IEC34 CSA C-22.2100, AS 1359, BS 1 6861, B En -6-610002:2001



#### **RATING GUIDELINES**

**PRIME POWER** rating corresponds to ISO Standard Power for continuous operation. It is applicable for supplying electrical power at variable load for an unlimited number of hours instead of commercially purchased power. A10 % overload capability for govering purpose is available for this rating.

**MAXIMUM STANDBY POWER** rating corresponds to ISO Standard Fuel Stop Power. It is applicable for supplying standby electrical power at variable load in areas with well established electrical networks in the event of normal utility power failure. No overload capability is available for this rating. I hp = I kW x 1.36

# **Engine Technical Data**

No. of Cylinders / Alignment	3 In Line
Cycle	4 Stroke
Aspiration	Turbocharged
Injection	Direct
Bore, mm	105
Stroke, mm	127
Displacement,I	3.3
Compression Ratio	17.25:1
Starting	12V Electric
Alternators, Amps	12V/65A


#### Alternator Technical Data

Alternator recinical Data	
No. of Bearings	Single Bearing
Insulation System	Class H
Excitation	Self Excited
Voltage Regulator	AS480
Protection	IP23
Temperature Rise,°C	125
Regulation	%1.0±
No. of Phases	3
No. of Poles	4

# **Dimensions & Weights**

 $Length(m) \ Width(m) \ Height(m) \ Weight(kg) \ Tank \ Capacity(L)$ 

1.85 0.75 1.3 810 95





# GGP46.8 GENSET

# Generating Set Powered By SPerkins STAMFORD

Performances	1500rpm	1800rpm
Alternator Efficiency	%87.9	%87.7
Engine Power Prime Power, KWm(hp) Standby Power, KWm(hp)	55.4)41.3) 61.2)45.6)	65.6)48.9) 72.3)53.9)
<b>Alternator</b> Prime Power, KWe	34	42


Lubrication System	I500rpm	1800rpm
Oil Consumption (I/hr)	%0.150 of fuel consumption	
Oil Sump Capacity,I	7.8	
Oil System Capacity Include Filters,I	8.3	

Cooling System	1500rpm	1800rpm
Heat Radiation from Engine and Alternator, Power KW	8	9
Heat Rejection to Coolant and Lube Oil at Standby Power, KW		34
Radiator Cooling Air Flow, m³/min (cfm)	2627)74.4)	3454)97.8)
Coolant Capacity, I	10.2	2

Intake & Exhaust System	I500rpm	1800rpm
Air Flow Combustion at Standby Power, m³/min(cfm)	109.4)3.1)	137.7)3.9)
Heat Rejection Exhaust at Standby Power, KW	35	43
Exhaust Gas Temperature at Standby °C	537	551
Max Allowable Back Pressure in Exhaust Line, Kpa	10.0	15.0
Exhaust Gas Flow at Standby Power, m³/min(cfm)	247)7.7)	335.4)9.5)

Accessories	
Oil Drain	Anti-Vibration Pads
Stainless Steel Flexible	Fuel Tank Base Frame for 8hrs
Standard Silencer	





**\** 07504483162 **-** 07704483162



# **Control Panel Readings**

- AC volts, AC currents, DC volts, frequency, rpm, hour counter, power factor.
- Low oil pressure, high water temparature, boost pressure and temperature, KW, KWh, KVA, KVAR
- Oil pressure, low oil level, high oil temperature
- DC alternator failure, over speed, over crank (Fail to start), over under voltage, over under current, any sensor failure
  • Low coolant level - Configurable inputs&outputs
- Upgradable for GSM network connection, Signal SMS messages.

## **Optional Equipment**

#### Engine

- -Coolant heater
- -Oversize batteries
- -Extra fuel pre-filter water separator
- -Battery Disconnector Switch
- -Electrical Governor
- Alternator
- -Excitation Boost System (EBS)
- -Upgrade to 3 phase sensing AVR
- -Qadrature droop kit
- -Anti-condensation heater
- -Air inlet filters
- General
- -Upgrade to modular controller for paralleling
- -Upgrade to 4 pole circuit breaker
- -Battery charger
- -Automatic transfer switch
- -Fuel level switch High / Low for alarm and control
- -Fuel transfer pump Automatic / Manual
- -Residential grade silencer
- -Weather protective and acoustic enclosure.

Genuine - Perkins
(1)
(I)
(I)
(I)
(I)

## **General Information**

# **Documentation**

Engine instruction book-English Alternator manual- English Wiring diagram

One year or 1000 thousand hours whichever elapsed first against all defects in material / or workmanship, subject to the terms and conditions of the Manufacturer's warranty.

